

**SCHUYLER-COLFAX MIDDLE SCHOOL  
1500 HAMBURG TURNPIKE**

**KEY:**

**TNR: TESTING NOT REQUIRED**

**DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION**

**ND: None Detected      BS: Below DEP / EPA Standard**

**Test Date 10/12/16**

<b>SAMPLE NUMBER</b>	<b>DESCRIPTION</b>	<b>TEST RESULTS</b>	<b>NOTES</b>
L6439857-1	LIBRARY OFFICE ROOM 139 SINK	ND	ND
L6439857-2	KITCHEN SINK ON ISLAND	11.600	BS
L6439857-3	FOUNTAIN BY CORRIDOR D	ND	ND
L6439857-4	WOOD SHOP FOUNTAIN	8.100	BS
L6439857-5	ART ROOM 133 SINK	ND	ND/TNR
L6439857-6	CLASSROOM 164 SINK	5.600	BS/TNR
L6439857-7	FOUNTAIN BY ROOM 151	ND	ND
L6439857-8	CLASS ROOM 124 FOUNTAIN	0.045	BS
L6439857-9	WOOD SHOP ROOM 136 SINK	ND	ND/TNR
L6439857-10	OFFICE FOUNTAIN BY CLASSROOM 155	5.400	BS
L6439857-11	KITCHEN SINK ON ISLAND BY FREEZER	4.500	BS
L6439857-12	WOOD SHOP SINK	TNR	TNR-SIGN POSTED
L6439857-13	KITCHEN SINK RIGHT	ND	ND
L6439857-14	FOUNTAIN BY CLASS ROOM 105	4.000	BS
L6439857-15	OFFICE FOUNTAIN BY CLASS ROOM 111	REMOVED	FOUNTAIN NOT REQUIRED
L6439857-16	GIRLS LOCKER ROOM OFFICE SINK	4.100	BS/TNR
L6439857-17	FOUNTAIN BY AUDITORIUM	ND	ND
L6439857-18	STORAGE RM SINK BY CORRIDOR D	TNR	TNR-SIGN POSTED
L6439857-19	FOUNTAIN BY BOYS LOCKER ROOM	ND	ND
L6439857-20	OFFICE SINK BY CLASS ROOM 155	ND	ND/TNR
L6439857-21	OFFICE FOUNTAIN BY ROOM 143	REMOVED	FOUNTAIN NOT REQUIRED
L6439857-22	MAIN OFFICE SINK	ND	ND
L6439857-23	KITCHEN SINK LEFT	1.500	BS
L6439857-24	NURSES OFFICE SINK	ND	ND
L6439857-25	CLASSRRM 101 SINK	TNR	TNR-SIGN POSTED
L6439857-26	CLASSROOM 103 SINK	4.100	TNR
L6439857-27	CLASSROOM 108 FOUNTAIN	REMOVED	FOUNTAIN NOT REQUIRED
L6439857-28	FOUNTAIN BY MAIN OFFICE	ND	ND
L6439857-29	GIRLS LOCKER ROOM MIDDLE SINK	2.300	BS/TNR
L6439857-30	OFFICE SINK BY ROOM 143	1.800	BS/TNR
L6439857-31	STORAGE ROOM SINK BY ROOM 135	ND	ND/TNR
L6439857-32	OFFICE SINK BY CLASSROOM 111	2.700	BS/TNR
L6439857-33	PREP ROOM SINK CLASSROOM 160	1.500	BS/TNR
L6439857-34	CLASSROOM SINK 168 SINK	4.500	BS/TNR
L6439857-35	ART ROOM 132 SINK	1.200	BS/TNR
L6439857-36	CLASSROOM 122 SINK	4.200	BS/TNR
L6439857-37	KITCHEN DOUBLE SINK ON ISLAND	2.300	BS

**SCHUYLER-COLFAX MIDDLE SCHOOL  
1500 HAMBURG TURNPIKE**

**KEY:**      **TNR: TESTING NOT REQUIRED**  
**DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION**  
**ND: None Detected      BS: Below DEP / EPA Standard**

**Test Date 10/12/16**

L6439857-38	CLASSROOM 140 SINK	ND	ND/TNR
L6439857-39	TEACHERS LOUNGE SINK	2.100	BS
L6439857-40	CLASSROOM 118 FOUNTAIN	REMOVED	FOUNTAIN NOT REQUIRED
L6439857-41	OFFICE SINK BY CLASS RM 106	2.700	BS/TNR
L6439857-42	CLASSROOM 124 SINK	7.700	BS/TNR
L6439857-43	CLASSROOM 118 SINK	3.200	BS/TNR
L6439857-44	BOYS LOCKER ROOM OFFICE SINK	1.900	BSTNR
L6439857-45	CLASSROOM 145 SINK	1.100	BS/TNR
L6439857-46	FOUNTAIN BY CLASSROOM 143	8.500	BS
L6439857-47	FOUNTIAN BY CLASSROOM 106	1.300	BS
L6439857-48	CLASSROOM 111 SINK	ND	ND
L6439857-49	FOUNTAIN BY TEACHERS LOUNGE	ND	ND
L6439857-50	CLASSROOM 102 SINK	REPLACED	TNR-SIGN POSTED
L6439857-51	WOOD SHOP 136 FOUNTAIN	2.700	BS
L6439857-52	CLASSROOM 160 SINK	12.500	BS/TNR
L6439857-53	CUSTODIAN OFFICE SINK	ND	ND
L6439857-54	CLASSROOM 164 FOUNTAIN	REMOVED	FOUNTAIN NOT REQUIRED
L6439857-55	CAFETERIA FOUNTAIN	ND	ND
L6439857-56	CLASSROOM 162 SINK	4.600	BS/TNR
L6439857-57	CLASSROOM 159 SINK	TNR	TNR-SIGN POSTED